

**RESOLUTION OF THE TOWNSHIP COUNCIL OF THE TOWNSHIP
OF MOUNT OLIVE APPROVING AN EMERGENCY PURCHASE
FOR REPAIRS ON THE FLANDERS SEWER PLANT AERATION TANK**

WHEREAS, on November 18, 2009 the sludge return air lift line at the Flanders Sewer Plant aeration tank developed a failure; and

WHEREAS, the line removes heavy sludge in the aeration tank which is a vital portion of the processing system; and

WHEREAS, the Director of Public Works had no alternative than to seek immediate repair of the situation and he immediately contacted Fletcher Creamer & Son, Inc. for repair services; and

WHEREAS, Fletcher Creamer & Son Inc., reported to the scene and estimated the cost for the repairs to be approximately \$27,000.00; and

NOW, THEREFORE BE IT RESOLVED by the Township Council of the Township of Mount Olive that it does hereby authorize an emergency purchase for the repairs on the Flanders Sewer Plant aeration tank at a cost of approximately \$27,000.

TOWNSHIP OF MOUNT OLIVE

Steve Rattner
Mt. Olive Council President

I, Lisa M. Lashway, Township Clerk of the Township of Mount Olive do hereby certify that the foregoing resolution is a true and correct copy of a resolution adopted at a legally convened meeting of the Mount Olive Township Council held on _____, 2009.

Lisa M. Lashway
Township Clerk